



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 19-10926

Inspection Number: 03553318

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 4363 IVYCREST PT HIGHLANDS RANCH

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

Inspection Details

Inspection Date: 05/07/2020

Inspection Time: 12:00 AM

Inspection Type: Final Building

Inspection Code: 108

Outcome: Approved

Inspected By: Chris Fuller

Charge Reinspection Fee: No

Comments

Smoke and CO test works.