



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 01-0110
Inspection Number: 00094723

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 10369 CHEETAH TAIL LITTLETON
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 01/12/2001
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: wvolz
Charge Reinspection Fee: No