



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: [dcbuilding@douglasco.gov](mailto:dcbuilding@douglasco.gov)

Permit Number: 18-04232  
Inspection Number: 03559515

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 1000 W NOE RD LARKSPUR  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 06/10/2020  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Plumbing  
**Inspection Code:** 40  
**Outcome:** Disapproved  
**Inspected By:** Kerry Keller  
**Charge Reinspection Fee:** No

### Comments

- 1) Need purple primer at H2o heater vent on all fitting
  - 2) Provide outside combustion air for H2o heater
  - 3) Secure Gas line at H2o heater
- Need H2o heater up and working for inspection