



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 18-04232
Inspection Number: 03559518

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 1000 W NOE RD LARKSPUR
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 06/10/2020
Inspection Time: 12:00 AM
Inspection Type: Final Building
Inspection Code: 108
Outcome: Disapproved
Inspected By: Kerry Keller
Charge Reinspection Fee: No

Comments

- 1) Paint black iron gas piping at gas regulator and south side exterior piping
- 2) Paint PVC flues and vents at rear upper roof
- 3) Seal around A/C line sets
- 4) Bottom rise is off at entry stairs both set of stairs
- 5) Adjust fire door closer so to self close
- 6) Provide gas shut off at fire place needs to be ready access