



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 19-14278  
Inspection Number: 03561071

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 4500 LAMBERT RANCH TRL SEDALIA  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Addition

### Inspection Details

**Inspection Date:** 06/17/2020  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Slab Electrical  
**Inspection Code:** 73  
**Outcome:** Disapproved  
**Inspected By:** Rick Sugar  
**Charge Reinspection Fee:** No

### Comments

Thermostat and control wire must be in a listed raceway  
NM box must be listed for a raceway  
Dedicated circuit.?