



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 19-12146
Inspection Number: 03565391

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 6832 YAMPA DR LARKSPUR
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 07/08/2020
Inspection Time: 1:08 PM
Inspection Type: Interior Gas Line
Inspection Code: 30
Meter Release:
Provider: Black Hills Energy
Outcome: Cancelled
Inspected By: UnassignedBldg
Charge Reinspection Fee: No

Comments

Cx by Norm