



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 00-2943
Inspection Number: 00045105

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 5454 GARTON RD CASTLE ROCK
Job Type: Building
Description: CM - Commercial
Scope of Work: New

Inspection Details

Inspection Date: 09/15/2000
Inspection Time: 12:00 AM
Inspection Type: Steel
Inspection Code: 17
Outcome: Approved
Inspected By: unknown
Charge Reinspection Fee: No

Comments

STEEL LETTER [LI NA]