



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 20-08037

Inspection Number: 03579088

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 11069 MEADOWVALE CIR HIGHLANDS RANCH

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

Inspection Details

Inspection Date: 09/16/2020

Inspection Time: 12:00 AM

Inspection Type: Rough Electric

Inspection Code: 22

Outcome: Approved

Inspected By: Matt Mazzara

Charge Reinspection Fee: No

Comments

Bond CSST at accessible hard pipe upstream #6cu

Check at final