



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 20-08037
Inspection Number: 03579089

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 11069 MEADOWVALE CIR HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 09/16/2020
Inspection Time: 12:00 AM
Inspection Type: Interior Gas Line
Inspection Code: 30
Meter Release: No
Provider:
Outcome: Approved
Inspected By: Chris Fuller
Charge Reinspection Fee: No

Comments

No changes to gas