



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 20-08037

Inspection Number: 03579090

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 11069 MEADOWVALE CIR HIGHLANDS RANCH

**Job Type:** Building

**Description:** RS - Basement

**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 09/16/2020

**Inspection Time:** 12:00 AM

**Inspection Type:** Rough Frame

**Inspection Code:** 29

**Outcome:** Approved

**Inspected By:** Chris Fuller

**Charge Reinspection Fee:** No

### Comments

Insulate mechanical room walls ceiling ductwork pipes by final

Egress ladder by final

Rotate water heater for 30 inch clearance in front by final.