



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 20-08037

Inspection Number: 03579091

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 11069 MEADOWVALE CIR HIGHLANDS RANCH

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

Inspection Details

Inspection Date: 09/16/2020

Inspection Time: 12:00 AM

Inspection Type: Underground Plumbing

Inspection Code: 12

Outcome: Approved

Inspected By: Chris Fuller

Charge Reinspection Fee: No