



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: [dcbuilding@douglasco.gov](mailto:dcbuilding@douglasco.gov)

Permit Number: 19-12146  
Inspection Number: 03585701

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 6832 YAMPA DR LARKSPUR  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 10/20/2020  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Shower Pan  
**Inspection Code:** 65  
**Outcome:** Approved  
**Inspected By:** Kerry Keller  
**Charge Reinspection Fee:** No