



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 20-02874  
Inspection Number: 03586280

## Building Inspection Report

Code Reviewed Under: 2018 IBC

### Permit Information

**Job Address:** 3380 E COUNTY LINE RD HIGHLANDS RANCH  
**Job Type:** Building  
**Description:** CM - Tenant Improvement  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 10/23/2020  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Rough Electric  
**Inspection Code:** 22  
**Outcome:** Disapproved  
**Inspected By:** Henry VanSchaack  
**Charge Reinspection Fee:** No

### Comments

1) fill unused ko in SE recep in luxor room; 2) nail plate required and secure mc at top plat above switch and recep on south wall of luxor room; 3) secure mc within 12" and 1-1/4" from face of framing on east wall of dog wash; 4) remove abandoned low-volt as far as possible per 725.25 in dog wash