



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 20-08037

Inspection Number: 03589621

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 11069 MEADOWVALE CIR HIGHLANDS RANCH

**Job Type:** Building

**Description:** RS - Basement

**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 11/10/2020

**Inspection Time:** 12:00 AM

**Inspection Type:** Final Building

**Inspection Code:** 108

**Outcome:** Disapproved

**Inspected By:** Chris Fuller

**Charge Reinspection Fee:** No

### Comments

Vapor barrier for insulation in mechanical room, ceiling too