



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 20-08037

Inspection Number: 03589622

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 11069 MEADOWVALE CIR HIGHLANDS RANCH

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

Inspection Details

Inspection Date: 11/10/2020

Inspection Time: 12:00 AM

Inspection Type: Final Electric

Inspection Code: 42

Outcome: Disapproved

Inspected By: Matt Mazzara

Charge Reinspection Fee: No

Comments

1)bath recep req GFCI protected

2)rec rm wall recep within 6' of bar sink req GFCI protected 210.8

3)Siemens breaker not listed for use in GE panel (bsmt sub)

4)bond CSST #6cu, main service or electrode to accessible hard pipe upstream