



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 20-08037

Inspection Number: 03590121

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 11069 MEADOWVALE CIR HIGHLANDS RANCH

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

Inspection Details

Inspection Date: 11/12/2020

Inspection Time: 12:00 AM

Inspection Type: Final Building

Inspection Code: 108

Outcome: Approved

Inspected By: Chris Fuller

Charge Reinspection Fee: No

Comments

Put plastic over ceiling insulation of mechanical room