



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 19-12146
Inspection Number: 03591957

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 6832 YAMPA DR LARKSPUR
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 11/20/2020
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Rick Sugar
Charge Reinspection Fee: No

Comments

Note no more than four openings on a small appliance circuit
2'4 foot rule at coffee bar in kitchen
Island outlet cannot exceed 6 inches of overhang at countertop
Main house kitchen hood not installed
Running boards required at north garage east wall and staircase
Kitchen hood not terminated and father-in-law Suite
Need location of GFCI to test soffit outlet
Light required at well disconnect in the crawlspace, need to inspect fuse size GFCI lights in crawlspace
Breaker locks required for kitchen hoods
Arc fault the kitchen hood circuits
Arc fault the stairway lighting in the father-in-law suite
#10 EGC at both AC units