



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 19-12146
Inspection Number: 03591958

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 6832 YAMPA DR LARKSPUR
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 11/20/2020
Inspection Time: 12:00 AM
Inspection Type: Final Building
Inspection Code: 108
Outcome: Disapproved
Inspected By: Kerry Keller
Charge Reinspection Fee: No

Comments

- 1) Need permanent address posted
- 2) Rear deck stairs is off on rise seven and three-quarter max rise
- 3) 4 inch max spear spacing at rear deck stairs risers
- 4) Install plug at rear patio gas shut off
- 5) Adjust fire door closers to self Close and latch
- 6) Missing fire door labels on three fire doors