



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 19-12146
Inspection Number: 03592843

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 6832 YAMPA DR LARKSPUR
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 11/24/2020
Inspection Time: 12:00 AM
Inspection Type: Final Defensible Space
Inspection Code: 61
Outcome: Approved
Inspected By: Jill Welle
Charge Reinspection Fee: No

Comments

Finishing