



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 19-02342

Inspection Number: 03597409

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 913 W WOLFENBERGER RD CASTLE ROCK

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 12/21/2020

Inspection Time: 12:00 AM

Inspection Type: Final Electric

Inspection Code: 42

Outcome: Disapproved

Inspected By: Rick Sugar

Charge Reinspection Fee: No

Comments

No more than 4 openings on a small appliance circuit

Gfci required within 6' of the rough plumbing in the 2 floor play room

Bond master bathroom tub

2 floor main hallway smoke detector has no power

Gfci required throughout the unfinished areas

Running boards in the unfinished areas

Furnace disconnect switch must indicate on/off

Secure FMC within 6' of panels

Inter system bonding terminal bar required

Appliance cord required at the water heater circulation pump

Label circuits at the garage sub panel

Note

Need to schedule a electrical service inspection