



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 19-02342

Inspection Number: 03597410

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 913 W WOLFENSBERGER RD CASTLE ROCK

**Job Type:** Building

**Description:** RS - Custom

**Scope of Work:** New

### Inspection Details

**Inspection Date:** 12/21/2020

**Inspection Time:** 12:00 AM

**Inspection Type:** Final Building

**Inspection Code:** 108

**Outcome:** Disapproved

**Inspected By:** Kerry Keller

**Charge Reinspection Fee:** No

### Comments

- 1} Paint PVC VENTS and complete furnace termination cap
- 2} Complete termination caps at rear soffits
- 3} Complete a landing at garage man door to exterior
- 4} Provide guardrail at upper sliding door off office
- 5} Cap off plumbing fixtures that not installed
- 6} Complete wood stove