



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 19-02342
Inspection Number: 03597411

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 913 W WOLFENSBERGER RD CASTLE ROCK
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 12/21/2020
Inspection Time: 12:00 AM
Inspection Type: Final Energy Compliance
Inspection Code: 109
Outcome: Approved
Inspected By: Kerry Keller
Charge Reinspection Fee: No