



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 19-02342

Inspection Number: 03598964

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 913 W WOLFENSBERGER RD CASTLE ROCK

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 01/04/2021

Inspection Time: 12:00 AM

Inspection Type: Electric Service Equipment

Inspection Code: 23

Meter Release: No

Provider: IREA

Outcome: Approved

Inspected By: Matt Mazzara

Charge Reinspection Fee: No

Comments

1)UFER clamp listing for 1 conductor

Correct and proceed

UFER left of bsmt panels