



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 21-00173

Inspection Number: 03603264

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 14952 VIENNA CIR PARKER

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

Inspection Details

Inspection Date: 01/26/2021

Inspection Time: 12:00 AM

Inspection Type: Rough Electric

Inspection Code: 22

Outcome: Disapproved

Inspected By: Jeremy Bock

Charge Reinspection Fee: No

Comments

1. solar pre-wire box in ceiling outside under stair closet must remain accessible
2. UFER location unknown-must remain accessible
3. additional support required-12/2 cable left of future sink-storage room wall