



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 21-00173

Inspection Number: 03603267

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 14952 VIENNA CIR PARKER

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

Inspection Details

Inspection Date: 01/26/2021

Inspection Time: 12:00 AM

Inspection Type: Fireblocking

Inspection Code: 112

Outcome: Approved

Inspected By: Richard Miller

Charge Reinspection Fee: No