



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 18-01266  
Inspection Number: 03605243

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 1510 N CASTLEWOOD CANYON RD FRANKTOWN  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 02/04/2021  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Justin Lett  
**Charge Reinspection Fee:** No

### Comments

1. Soffit recepts to have WR type recep and damp rated covers-provide ladder to test 2. Need access to all garage walls to test recepts as well as ladder to access ceiling recepts 3. Label kit circuits by location 4. Hood wiring incomplete 5. Attic furnace switch required to be indicating and label 6. Ejector and sump recepts require GFCI protection 7. Label all breakers in sub 8. Label breakers for furnaces by location 9. Max 90A on #2 SER