



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 18-01266
Inspection Number: 03605243

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 1510 N CASTLEWOOD CANYON RD FRANKTOWN
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 02/04/2021
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Justin Lett
Charge Reinspection Fee: No

Comments

1. Soffit recepts to have WR type recep and damp rated covers-provide ladder to test 2. Need access to all garage walls to test recepts as well as ladder to access ceiling recepts 3. Label kit circuits by location 4. Hood wiring incomplete 5. Attic furnace switch required to be indicating and label 6. Ejector and sump recepts require GFCI protection 7. Label all breakers in sub 8. Label breakers for furnaces by location 9. Max 90A on #2 SER