

Douglas County Building Division 100 Third Street STE #20 Castle Rock, CO 80104 Phone: 303.660.7497 Email: dcbuilding@douglas.co.us

> Permit Number: 18-01266 Inspection Number: 03606782

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 1510 N CASTLEWOOD CANYON RD FRANKTOWN Job Type: Building Description: RS - Custom Scope of Work: New

Inspection Details

Inspection Date: 02/11/2021 Inspection Time: 12:00 AM Inspection Type: Final Electric Inspection Code: 42 Outcome: Disapproved Inspected By: Justin Lett Charge Reinspection Fee: No

Comments

1. Soffit recep switch requires AFCI protection per 210.12 2. Attic furnace disconnect switch required to be of the indicating type per 422.35 (Single pole toggle type)