



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 21-02174  
Inspection Number: 03612075

## Building Inspection Report

### Permit Information

**Job Address:** 663 WALDEN CT HIGHLANDS RANCH  
**Job Type:** Electrical  
**Description:** Service Change/Upgrade

### Inspection Details

**Inspection Date:** 03/10/2021  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Matt Mazzara  
**Charge Reinspection Fee:** No

### Comments

- 1)handle tie req multiwire branch circuit disposal/dishwasher
- 2)inter system bond req at service
- 3)1 conductor per grd rod clamp
- 4)cold water pipe GEC must terminate within first 5' of entry