



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 21-00698  
Inspection Number: 03620582

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

Job Address: 5771 DISTANT VIEW PL PARKER  
Job Type: Building  
Description: RS - Custom  
Scope of Work: New

### Inspection Details

Inspection Date: 04/26/2021  
Inspection Time: 12:00 AM  
Inspection Type: Construction Meter  
Inspection Code: 10  
Meter Release:  
Provider: IREA  
Outcome: Disapproved  
Inspected By: Henry VanSchaack  
Charge Reinspection Fee: No

### Comments

1) neutral smaller than #4 requires white insulation per 200.6; 2) panel neutral not permitted to be bonded to ground/enclosure per 250.24