Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 21-04169
Inspection Number: 03626976

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 10662 HILLROSE ST PARKER
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 05/25/2021
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Thomas Buzo
Charge Reinspection Fee: No

Comments

1) Bundling above new subpanel seven homeruns bundled together with cable tie. need to derate or maintain separation. 310.15
2) Provide listing for cable zip ties. Cable ties need to be listed and identified for securement and support. 334.30
3) Provide proper working clearance in front of sub panel. 110.26

#6 AL SER check sub panel breaker