



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 21-01668
Inspection Number: 03627787

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 2999 FURTHERMORE LN CASTLE ROCK
Job Type: Building
Description: AU - Solar
Scope of Work: Alteration

Inspection Details

Inspection Date: 05/27/2021
Inspection Time: 5:35 PM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: Thomas Buzo
Charge Reinspection Fee: No

Comments

Partial Rough In wall only.