Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 21-05774
Inspection Number: 03636418

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 9318 FRASER RIVER ST LITTLETON
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 07/08/2021
Inspection Time: 1:12 PM
Inspection Type: Rough Frame
Inspection Code: 29
Outcome: Approved
Inspected By: Robert Stratton
Charge Reinspection Fee: No