



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 21-05289
Inspection Number: 03639286

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 9506 CHERRYVALE DR HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 07/21/2021
Inspection Time: 11:11 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Matt Mazzara
Charge Reinspection Fee: No

Comments

1)4 wire req to double oven
2)micro ded?
3)NP top plate above kitchen 3gang
4)secure LV to maintain 1" clearance to bsmt FP
5)NP by bsmt powder vanity
Note:per Doug Co amendments max 10 openings 15amp circuits, 12 openings 20amp circuits and 4 openings 20amp small appliance circuits that serve kit counter tops