



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 21-05289  
Inspection Number: 03639287

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 9506 CHERRYVALE DR HIGHLANDS RANCH  
**Job Type:** Building  
**Description:** RS - Basement  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 07/21/2021  
**Inspection Time:** 2:03 PM  
**Inspection Type:** Interior Gas Line  
**Inspection Code:** 30  
**Meter Release:** No  
**Provider:**  
**Outcome:** Approved  
**Inspected By:** Chris Fuller  
**Charge Reinspection Fee:** No

### Comments

Fireplace holding at 10