



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 21-05289
Inspection Number: 03641868

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 9506 CHERRYVALE DR HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 08/02/2021
Inspection Time: 1:01 PM
Inspection Type: Drywall
Inspection Code: 38
Outcome: Approved
Inspected By: Chris Fuller
Charge Reinspection Fee: No

Comments

Basmt