



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 21-07749
Inspection Number: 03644026

Building Inspection Report

Permit Information

Job Address: 3044 DOGWOOD AVE PARKER
Job Type: Mechanical
Description: Furnace/AC Combo (Primary Residence)

Inspection Details

Inspection Date: 08/11/2021
Inspection Time: 3:02 PM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Henry VanSchaack
Charge Reinspection Fee: No

Comments

- 1) bond air handler disconnect in attic
- 2) air handler maximum ocpd 15a per label
- 3) label air handler ckt in panel
- 4) fill unused breaker space in panel
- 5) condenser maximum ocpd 25a per label