



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 21-07749  
Inspection Number: 03644026

## Building Inspection Report

### Permit Information

**Job Address:** 3044 DOGWOOD AVE PARKER  
**Job Type:** Mechanical  
**Description:** Furnace/AC Combo (Primary Residence)

### Inspection Details

**Inspection Date:** 08/11/2021  
**Inspection Time:** 3:02 PM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Henry VanSchaack  
**Charge Reinspection Fee:** No

### Comments

- 1) bond air handler disconnect in attic
- 2) air handler maximum ocpd 15a per label
- 3) label air handler ckt in panel
- 4) fill unused breaker space in panel
- 5) condenser maximum ocpd 25a per label