



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 21-02361
Inspection Number: 03644323

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 8099 MOUNT OURAY RD LITTLETON
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 08/11/2021
Inspection Time: 12:14 PM
Inspection Type: Underground Plumbing
Inspection Code: 12
Outcome: Approved
Inspected By: Chris Fuller
Charge Reinspection Fee: No