Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 21-00698
Inspection Number: 03644610

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 5771 DISTANT VIEW PL PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 08/11/2021
Inspection Time: 3:18 PM
Inspection Type: Rough Plumbing
Inspection Code: 28
Outcome: Cancelled
Inspected By: Rick Chadwick
Charge Reinspection Fee: No

Comments

No eng letters.