



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 21-02361
Inspection Number: 03646345

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 8099 MOUNT OURAY RD LITTLETON
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 08/20/2021
Inspection Time: 10:38 AM
Inspection Type: Construction Meter
Inspection Code: 10
Meter Release:
Provider: Xcel
Outcome: Disapproved
Inspected By: Damon Montroy
Charge Reinspection Fee: No

Comments

1. Panel door not connected to panel
2. Fill unused breaker slots