



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 21-07749
Inspection Number: 03646676

Building Inspection Report

Permit Information

Job Address: 3044 DOGWOOD AVE PARKER
Job Type: Mechanical
Description: Furnace/AC Combo (Primary Residence)

Inspection Details

Inspection Date: 08/23/2021
Inspection Time: 11:21 AM
Inspection Type: Final HVAC
Inspection Code: 39
Outcome: Approved
Inspected By: Henry VanSchaack
Charge Reinspection Fee: No