



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 21-00698  
Inspection Number: 03646979

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

Job Address: 5771 DISTANT VIEW PL PARKER  
Job Type: Building  
Description: RS - Custom  
Scope of Work: New

### Inspection Details

Inspection Date: 08/24/2021  
Inspection Time: 12:58 PM  
Inspection Type: Roof Truss  
Inspection Code: 127  
Outcome: Disapproved  
Inspected By: Carlo Turchiano  
Charge Reinspection Fee: No

### Comments

Check uplift at mid bearing point G5, G3, S6-S13, T18, T19