Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 21-00698
Inspection Number: 03647336

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 5771 DISTANT VIEW PL PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 08/25/2021
Inspection Time: 9:19 AM
Inspection Type: Roof Truss
Inspection Code: 127
Outcome: Disapproved
Inspected By: Richard Miller
Charge Reinspection Fee: No

Comments

Need bearing blocks on trusses listed in previous inspection at mid point bearing