Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 21-00072
Inspection Number: 03647542

Building Inspection Report

Permit Information

Job Address: 511 HELENA CIR LITTLETON
Job Type: Electrical
Description: Service Change/Upgrade

Inspection Details

Inspection Date: 08/25/2021
Inspection Time: 12:12 PM
Inspection Type: Electric Service Equipment
Inspection Code: 23
Meter Release:
Provider:
Outcome: Disapproved
Inspected By: Henry VanSchaack
Charge Reinspection Fee: No

Comments

Gec to second ground rod must run directly to main panel neutral bar, first ground rod or to water pipe within first 5’ of water entr, not permitted from sub-panel equipment ground bar