Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 21-00698
Inspection Number: 03648554

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 5771 DISTANT VIEW PL PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 08/31/2021
Inspection Time: 12:18 PM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Justin Lett
Charge Reinspection Fee: No

Comments

1. Dry in garage doors 2. 15A Circuits exceed 10 openings. Comply with DC amendments 3. Correct wall space at bookshelf outside of exercise rm