



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 21-02361  
Inspection Number: 03648975

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 8099 MOUNT OURAY RD LITTLETON  
**Job Type:** Building  
**Description:** RS - Stock  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 09/01/2021  
**Inspection Time:** 1:30 PM  
**Inspection Type:** Exterior Wall Sheathing  
**Inspection Code:** 104  
**Outcome:** Cancelled  
**Inspected By:** Fredrick Mooney  
**Charge Reinspection Fee:** No

### Comments

Brian cancelled