



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 21-00698
Inspection Number: 03650550

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 5771 DISTANT VIEW PL PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 09/09/2021
Inspection Time: 11:30 AM
Inspection Type: Electric Trench
Inspection Code: 16
Outcome: Approved
Inspected By: Thomas Buzo
Charge Reinspection Fee: No

Comments

Electric trench ok from pedestal to se corner of house. 2-4/0, 1-2/0, 1-1AWG.

Protect direct burial conductor down to 18" below finish grade. Leave trench open at house to check at electric service equipment inspection.