



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 21-02361
Inspection Number: 03651139

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 8099 MOUNT OURAY RD LITTLETON
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 09/13/2021
Inspection Time: 3:11 PM
Inspection Type: Weather Resistive Barrier
Inspection Code: 132
Outcome: Approved
Inspected By: Clayton Rodeback
Charge Reinspection Fee: No