Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 21-00698
Inspection Number: 03651157

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 5771 DISTANT VIEW PL PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 09/14/2021
Inspection Time: 7:29 AM
Inspection Type: Insulation Thermal
Inspection Code: 36
Outcome: Disapproved
Inspected By: Fredrick Mooney
Charge Reinspection Fee: No

Comments

requested pictures of missing vapor barrier and sill seal. Never received them.
Do not proceed with drywall on first floor. recall thermal inspection.